



SECTION 08625

TUBULAR DAYLIGHTING DEVICE

Display hidden notes to specifier. (Don't know how? [Click Here](#))

PART 1 GENERAL

1.1 SECTION INCLUDES

- A. Tubular daylighting device, consisting of roof dome, reflective tube, and diffuser assembly; configuration as indicated on the drawings.
- B. Accessories.

1.2 RELATED SECTIONS

- A. Section 07311 - Asphalt Shingles: Flashing of skylight base.
- B. Section 07320 - Roof Tiles: Flashing of skylight base.
- C. Section 07510 - Built-Up Bituminous Roofing: Flashing of skylight base.
- D. Section 07530 - Electrometric Membrane Roofing: Flashing of skylight base.
- E. Section 07550 - Modified Bituminous Membrane Roofing: Flashing of skylight base.
- F. Section 07600 – Flashing: Metal flashings.
- G. Section 08620 - Unit Skylights: Skylights without reflective tube.
- H. Section 08630 - Metal Framed Skylights.
- I. Section 15810 - Ducts: Fan vent duct and connections.
- J. Section 16150 - Equipment Wiring: Electrical connections.
- K. Section 16500 – Lighting Equipment and Controls: Light bulbs and lamps.

1.3 REFERENCES

- A. ASTM B 209 - Standard Specification for Aluminum and Aluminum-Alloy Sheet and Plate.
- B. ASTM E 84 - Standard Test Method for Surface Burning Characteristics of Building Materials; 2008a.

- C. ASTM A 463/A 463M - Standard Specification for Steel Sheet, Aluminum Coated, by the Hot Dip Process; 2006.
- D. ASTM A 653/A 653M - Standard Specification for Steel Sheet, Zinc Coated (Galvanized), by the Hot Dip Process; 2007.
- E. ASTM A792/A 792M – Standard Specification for Steel Sheet, 55% Aluminum-Zinc Alloy-Coated by the Hot-Dip Process
- F. ASTM E 283 - Test Method for Rate of Air Leakage Through Exterior Windows, Curtain Walls, and Doors Under Specified Pressure Differences Across the Specimen; 2004.
- G. ASTM E 308 - Standard Practice for Computing the Colors of Objects by Using the CIE System; 2006.
- H. ASTM E 330 - Structural Performance of Exterior Windows, Curtain Walls and Doors; 2002.
- I. ASTM E 547 - Test Method for Water Penetration of Exterior Windows, Skylights, Doors and Curtain walls by Cyclic Air Pressure Difference; 2000.
- J. ASTM E 1886 - Standard Test Method for Performance of Exterior Windows, Curtain Walls, Doors, and Impact Protective Systems Impacted by Missile(s) and Exposed to Cyclic Pressure Differentials.
- K. ASTM E 1996 - Standard Specification for Performance of Exterior Windows, Curtain Walls, Doors, and Impact Protective Systems Impacted by Windborne Debris in Hurricane
- L. ASTM D 635 - Test Method for Rate of Burning and/or Extent of Time of Burning of Self-Supporting Plastics in a Horizontal Position; 2006.
- M. ASTM D-1929 - Test Method for Ignition Properties of Plastics; 1996 (2001).
- N. UL 181 - Factory Made Air Ducts and Air Connectors
- O. ICC AC-16 - Acceptance Criteria for Plastic Skylights; 2008.
- P. Florida Building Code TAS 201 – Impact Test Procedures.
- Q. Florida Building Code TAS 202 – Criteria for Testing Impact and Non Impact Resistant Building Envelope Components Using Uniform Static Air Pressure Loading.
- R. Florida Building Code TAS 203 – Criteria for Testing Products Subject to Cyclic Wind Pressure Loading

1.4 PERFORMANCE REQUIREMENTS

- A. Completed tubular daylighting device assemblies shall be capable of meeting the following performance requirements:

1. Air Infiltration Test: Air infiltration will not exceed 0.30 cfm/sf aperture with a pressure delta of 1.57 psf across the tube when tested in accordance with ASTM E 283.
2. Water Resistance Test: No uncontrolled water leakage at 10.5 psf pressure differential with water rate of 5 gallons/hour/sf when tested in accordance with ASTM E 547.
3. Uniform Load Test:
 - a. No breakage, permanent damage to fasteners, hardware parts, or damage to make daylighting system inoperable or cause excessive permanent deflection of any section when tested at a Positive Load of 150 psf (7.18 kPa) or Negative Load of 70 psf (3.35 kPa).
 - b. All units shall be tested with a safety factor of (3) for positive pressure and (2) for negative pressure, acting normal to plane of roof in accordance with ASTM E 330.
4. Hurricane Resistance:
 - a. Meets Florida Building Code TAS, 201, TAS, 202 and TAS 203 for Impact and non impact components.
 - b. Meets ASTM E 1886 and ASTM E1996 for missile and cyclic pressure differential testing.
5. Fire Testing:
 - a. When used with the Dome Edge Protection Band, all domes meet fire rating requirements as described in the 2006 International Building Code.
 - b. Self-Ignition Temperature - Greater than 650 degrees F per ASTM D-1929.
 - c. Smoke Density - Rating no greater than 450 per ASTM Standard E 84 in way intended for use. Classification C.
 - d. Rate of Burn and/or Extent - Maximum Burning Rate: 2.5 inches/min (62 mm/min) Classification CC-2 per ASTM D 635.
 - e. Rate of Burn and/or Extent - Maximum Burn Extent: 1 inch (25 mm) Classification CC-1 per ASTM D 635.

1.5 SUBMITTALS

- A. Submit under provisions of Section 01300.
- B. Product Data: Manufacturer's data sheets on each product to be used, including:
 1. Preparation instructions and recommendations.
 2. Storage and handling requirements and recommendations.
 3. Installation methods.
- C. Shop Drawings. Submit shop drawings showing layout, profiles and product components, including anchorage, flashings and accessories.
- D. Verification Samples: As requested by Architect.
- E. Test Reports: Independent testing agency or evaluation service reports verifying compliance with specified performance requirements.
- F. LEED Submittals: Provide documentation of how the requirements of Credit will be met:
 1. List of Daylight Credits available for the products specified.
 2. Data on Energy Optimization Performance Credits for the products specified.

3. Data on Regional Credits which may be available for the project location. (LEED 2.1)
4. Data on Perimeter and Non-Perimeter Controllability of Systems for use of Daylight Dimmer option with the products specified.
5. Data on potential Innovation in Design Credits which may be available for the innovative use of the products specified.

1.6 QUALITY ASSURANCE

- A. Manufacturer Qualifications: Engaged in manufacture of tubular daylighting devices for minimum 15 years.

1.7 DELIVERY, STORAGE, AND HANDLING

- A. Store products in manufacturer's unopened packaging until ready for installation.
- B. Store and dispose of solvent-based materials, and materials used with solvent-based materials, in accordance with requirements of local authorities having jurisdiction.

1.8 PROJECT CONDITIONS

- A. Maintain environmental conditions (temperature, humidity, and ventilation) within limits recommended by manufacturer for optimum results. Do not install products under environmental conditions outside manufacturer's absolute limits.

1.9 WARRANTY

- A. Daylighting Device: Manufacturer's standard warranty for 10 years.
- B. Electrical Parts: Manufacturer's standard warranty for 5 years, unless otherwise indicated.

PART 2 PRODUCTS

2.1 MANUFACTURERS

- A. Acceptable Manufacturer: Solatube International, Inc.; 2210 Oak Ridge Way, Vista, CA 92081. ASD. Tel. Toll Free: 888-765-2882. Tel: (760) 477-1120. Fax: (760) 597-4488. Email: commsales@solatube.com. Web: www.solatube.com.
- B. Substitutions: Not permitted.
- C. Requests for substitutions will be considered in accordance with provisions of Section 01600.
- D. General Contractor will bear responsibility for costs associated with substitution review.
- E. Requests for substitutions will be considered provided a lighting layout with photometric data is supplied to demonstrate light levels will meet original design intent.

2.2 TUBULAR DAYLIGHTING DEVICES

- A. Tubular Daylighting Devices General : Transparent roof-mounted skylight dome and self-flashing curb, reflective tube, and ceiling level diffuser assembly, transferring sunlight to interior spaces; complying with ICC AC-16.
- B. SolaMaster Series: Solatube Model 330 DS-O Open Ceiling, 21 inch (530 mm) Daylighting System:
 - 1. Roof Dome Assembly: Transparent, UV and impact resistant dome with flashing base supporting dome and top of tube.
 - a. Glazing: Type DA, 0.143 inch (3.7 mm) minimum thickness injection molded acrylic classified as CC2 material; UV inhibiting (100 percent UV C, 100 percent UV B and 98.5 percent UV A), impact modified acrylic blend.
 - 2. LightTracker Reflector, made of aluminum sheet, thickness 0.015 inch (0.4 mm) with Spectralight Infinity. Positioned in the dome to capture low angle sunlight.
 - 3. Roof Flashing Base:
 - a. One Piece: One piece, seamless, leak-proof flashing functioning as base support for dome and top of tube. Sheet steel, corrosion resistant conforming to ASTM A 653/A 653M or ASTM A 463/A 463M, or ASTM A 792/A792 M, 0.028 inch (0.7 mm) plus or minus .006 inch (.015 mm) thick.
 - 1) Base Style: Type F4, Self mounted, 4 inches (102 mm) high.
 - 2) Base Style: Type F8, Self mounted, 8 inches (203 mm) high.
 - 3) Base Style: Type F11, Self mounted, 11 inches (279 mm) high.
 - 4) Base Style: Type FC, Curb cap, with inside dimensions of 27 inches by 27 inches (685 mm x 685 mm) to cover curb as specified in Section 07600.
 - b. Two Piece: Two-piece, inverted flange Metal Roof Flashing for Standing Seam Rib roof profile with greater than 14-3/8 inch (365 mm) minimum distance between ribs permitting a required greater than 2 inch (51 mm) clearance between flashing and rib: Type FSM. Aluminum 1060 Alloy, corrosion resistant conforming to ASTM B 209, 0.059 inch (1.5 mm) thick.
 - 4. Flashing Insulator: Type FI, Thermal isolation material for use under flashing.
 - 5. Curb Insulator: Type CI, Thermal isolation material for use at curb base.
 - 6. Dome Edge Protection Band: Type PB, For fire rated roofs with turret height less than 8 inches (203 mm). Galvanized steel. Nominal thickness of 0.039 inch (1 mm).
 - 7. Roof Flashing Turret Extensions: Provide manufacturer's standard extensions for applications requiring:
 - a. Type T12: Additional lengths of 12 inches (300 mm) extension.
 - b. Type T24: Additional lengths of 24 inches (600 mm) extension.
 - c. Type T36: Additional lengths of 36 inches (900 mm) extension.
 - d. Type T48: Additional lengths of 48 inches (1200 mm) extension.
 - 8. Tube Ring: Attached to top of base section; 0.090 inch (2.3 mm) nominal thickness injection molded high impact PVC; to prevent thermal bridging between base flashing and tubing and channel condensed moisture out of tubing.
 - 9. Tube Ring Seal: Attached to the base of the dome ring; butyl glazing rope, 0.24 inch (6 mm) diameter; to minimize air infiltration.
 - 10. Dome Seal: Adhesive backed weatherstrip, 0.63 inch (16 mm) tall by 0.28 inch (7 mm).
 - 11. Reflective Tubes: Aluminum sheet, thickness 0.018 inch (0.5 mm).
 - a. General:

- 1) Interior Finish: Spectralight Infinity high reflectance specular finish on exposed reflective surface. Specular reflectance for visible spectrum (400 nm to 760 nm) greater than 99 percent. Total solar spectrum reflectance (400 nm to 2500 nm) less than 80.2 percent.
 - 2) Color: a* and b* (defined by CIE L*a*b* color model) shall not exceed plus 2 or be less than minus 2 as determined in accordance to ASTM E 308.
 - b. Top Tube Angle Adapter, Type TA:
 - 1) Reflective 45 degree adjustable Top Tube Angle Adapter, 16 inches (406 mm) long.
 - c. Bottom Tube Angle Adapter, Type BA:
 - 1) Reflective 45 degree adjustable Bottom Tube Angle Adapter, 16 inches (406 mm) long
 - d. Top Tube Angle Adapter and Bottom Tube Angle Adapter Kit, Type AK:
 - 1) Reflective 45 degree adjustable top and bottom angle adapters (one each), 16 inches (406 mm) long
 - e. Extension Tube:
 - 1) Reflective extension tube, Type EXX, Notched for Open Ceiling diffuser attachment, 24 inches (610 mm) or 48 inches (1220 mm) long.
 - f. Reflective 90 degree Adjustable tube:
 - 1) Extension Tube Angle Adapter: Provide manufacturer's standard adapters for applications requiring:
 - (a) Type A1 one 0 to 90 degree extension tube angle adapter.
 - (b) Type A2 two 0 to 90 degree extension tube angle adapters.
12. Diffuser Assemblies for Tubes Not Penetrating Ceilings (Open Ceiling): Solatube Model 330 DS-O. 21 inch (530 mm) diameter diffuser attached directly to bottom of tube.
- a. Lens: Type L1 OptiView Fresnel lens design to maximize light output and diffusion. Visible Light Transmission shall be greater than 90 percent at 0.022 inch (0.6 mm) thick. Classified as CC2.
 - b. Lens: Type L2, Prismatic lens designed to maximize light output and diffusion. Visible Light Transmission shall be greater than 90 percent at 0.100 inch (2.5 mm) thick. Classified as CC2.
 - c. Diffuser Seal: Open cell foam, acrylic adhesive backed, 0.75 inch (19 mm) wide by 0.125 inch (3.2 mm) thick to minimize condensation and bug, dirt and air infiltration per ASTM E 283.
 - d. Diffuser Trim Ring: Injection molded acrylic. Nominal wall thickness 0.172 inches (4.4 mm).
 - e. Secondary Diffuser: Type SS, Acrylic plastic classified as CC2 material. Thickness shall not be less than 0.100 inches.
13. Accessories:
- a. Security Bar: Type B Security Bar 0.375 inch (95 mm) stainless steel bar across flashing diameter opening.
 - b. Security Kit: Type SK Dome Security Kit, rivets with nylon spacers to replace dome screws.
 - c. Open ceiling trim ring: Type R, ABS Plastic, White; nominal thickness of 0.04 inches (1 mm).
 - d. Wire Suspension Kit: Type E, Use the wire suspension kit when additional bracing to the structure is required.

- e. Local Dimmer Control utilizing a butterfly baffle design of Spectralight Infinity reflective material to minimize shadowing when in use: Provided with dimmer switch and cable.
 - 1) Daylight Dimmer: Type D Electro-mechanically actuated daylight valve; for universal input voltages ranging between 90 and 277 V at 50 or 60 Hz; maximum current draw of 50 ma per unit; controlled by low voltage, series Type T02: circuited, 4 conductor, size 22 cable; providing daylight output between 2 and 100 percent. Provided with dimmer switch and cable.
 - 2) Switch: Type SW, Manufacturer-specific low voltage DC DP/DT switch (white) required to operate Daylight Dimmer. Note: only one switch is required per set of synchronously controlled dimmers.
 - 3) Cable: Type CA, Two conductor low voltage cable (500 foot) for multiple unit DC connection.
- f. Thermal Insulation Panel: Type TIP, high-performance dual-glazed, thermally-broken tube insulation system consisting of two acrylic panels, spaced 1.0 inch (25.4mm) apart, classified CC2 Class C material, 0.110 inch (2.8 mm) thick, housed in a polyethylene terephthalate glycol-modified (PETG) or acrylonitrile butadiene styrene (ABS) band classified as CC2 material 0.060 inch (1.5 mm) thick by 1.75 inch (44.5 mm) high with Spectralight Infinity high reflectance specular finish interior surface, and assembled with stainless steel disk spacers 0.0197 inch (0.5 mm) thick and aluminum rivets 0.13 inch (3.2 mm) fastened periodically around the perimeter.

2.3 ACCESSORIES

- A. Fasteners: Same material as metals being fastened, non-magnetic steel, non-corrosive metal of type recommended by manufacturer, or injection molded nylon.
- B. Suspension Wire: Steel, annealed, galvanized finish, size and type for application and ceiling system requirement.
- C. Sealant: Polyurethane or copolymer based elastomeric sealant as provided or recommended by manufacturer.

PART 3 EXECUTION

3.1 EXAMINATION

- A. Do not begin installation until substrates have been properly prepared.
- B. If substrate preparation is the responsibility of another installer, notify Architect of unsatisfactory preparation before proceeding.

3.2 PREPARATION

- A. Clean surfaces thoroughly prior to installation.
- B. Prepare surfaces using the methods recommended by the manufacturer for achieving the best result for the substrate under the project conditions.

3.3 INSTALLATION

- A. Install in accordance with manufacturer's printed instructions.
- B. After installation of first unit, field test to determine adequacy of installation. Conduct water test in presence of Owner, Architect, or Contractor, or their designated representative. Correct if needed before proceeding with installation of subsequent units.

3.4 PROTECTION

- A. Protect installed products until completion of project.
- B. Touch-up, repair or replace damaged products before Substantial Completion.

END OF SECTION